

**Gale Siviter (Neighbourhood Services)**

**From:** Neil Aston-Baugh <Neil.Aston-Baugh@wmfs.net>  
**Sent:** 03 April 2024 09:25  
**To:** Liquor Licensing; Nick Slym (Neighbourhood Services)  
**Cc:** ronnieswoodfired@gmail.com; Antonia Gillespie; dy licensing; Daniel O'Keeffe (Environmental Health and Trading Standards)  
**Subject:** [EXTERNAL EMAIL] Fire Authority representation to a premises licence application

**CAUTION:** This email originated from outside of the council. Do not click links or open attachments unless you are sure the content is safe.

OFFICIAL

**LICENSING ACT 2003**  
**NAME OF PREMISES: Ronnies Wood fired Pizza**  
**ADDRESS: First Floor, 119-120 High Street, Stourbridge DY8 1DT**

I refer to the application for the Grant of a Premises Licence, made in respect of the above premises. I visited the premises on Tuesday 2<sup>nd</sup> April at 11:30am for a pre-arranged appointment but the applicant failed to attend.

Even though I couldn't fully access the building I can confirm that there are some Fire Safety issues that affect the licensing Objective of Public Safety.

- The Fire Alarm does not appear to be working correctly

**Consequently, The Fire Authority hereby makes representation to the application.**

The Fire Authority will not remove its representation until it has been provided with evidence (such as a suitable certificate) that the fire alarm has been serviced in accordance with BS5839-1 and is working efficiently and effectively.

Should you require any further information or clarification, please do not hesitate to contact me.

In addition to the above, the premises were recently inspected by this Authority and a number of fire safety issues were identified.

I must inform you (as the licensing Authority) under Article 42 of the Regulatory Reform Fire Safety Order 2005, of any actions that this Authority takes on a premises licenced by you. As the premises are not yet licenced, the letter does not form part of the representation, but is for your information only. The matters contained within the letter will be followed up by us to ensure the licensing objective of Public Safety is further promoted.

*Regards*

*Neil Aston-Baugh*

Fire Safety Officer -LEEPS Team  
 Tipton Fire Station  
 Alexandra Road  
 Tipton  
 West Midlands  
 DY4 7NZ  
 Tel: 07973 810 042 or,  
 0121 380 7500

Email : [neil.aston-baugh@wmfs.net](mailto:neil.aston-baugh@wmfs.net)

**Team Email:** [LEEPSTeams.Enquiries@wmfs.net](mailto:LEEPSTeams.Enquiries@wmfs.net)

Fire Safety Admin Email [firesafety.admin@wmfs.net](mailto:firesafety.admin@wmfs.net)